

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION

CERTIFICATE

No. NSIA 2025-26

Dated: 22/7/25

It is certified that an inspection team headed by Dr. Anurag Katiyar

(Name of Officers with designation) from P. H. C. Wagholi PHED

inspected the North Star International Academy

(Name & Address of the school) on 22/7/25 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. SPHLE PUNE dated 22/7/25 of

State Public Health Lab Pune (PHED Lab) certified that the

North Star International Academy (Name of school) has safe drinking water facilities for the students

and members of staff of the Institution. School is also maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till Dec 25

Signature with Seal: [Signature]

Name: वैद्यकीय अधिकारी

Designation: प्रमुख आरोग्य केंद्र वाघोली,

Name & Address of the Office / Department: P. H. C. Wagholi

To

Nirmala Memorial Foundation's




North Star International Academy

JSPM College Road, Near Nyati Elan

Nagar Highway

Wagholi 412207

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

					
STATE PUBLIC HEALTH LABORATORY, PUNE					
Dy Director tele No. Office Tele No.	26330509 (P) 26330225 (O)	Cantonment water works campus, Near Saint Mary Church, Staveley road, Pulgate, Pune-411 001 (MH) INDIA Email ID : sphlmis@gmail.com , statehealthlab@gmail.com website : arogya.maharashtra.gov.in			
HEALTH SERVICES:	No.SPHLPUNE/Desk-80/Bact.Section/water analysis report/ 1082 / 2025 Date : 22/7/25 2025				

Bacteriological Report of water Sample

Sender's Name	Norh Star International Academy, Beside JSPM College, Bakori Phata, Wagholi, Pune- 412207.
Sendr's letter No. & date	--/ 18-07-2025
Lab. Reference No.	142 / 803
Date of sample collection	18/07/2025
Date of sample received	18/07/2025
Analysis start date	18/07/2025

	Sample Description	Bacteriological Analysis result			
		Most Probable Number of bacteria found per 100 ml of Water Sample			
		Coliforms	Thermotolerant Coliforms	<u>E.coli</u>	Conclusion
1.	NSIA, Wagholi, Pune – R.O. Water (Tanker)	0	-	-	Potable

Remark: If water sample found non-potable, it can be used for drinking purposes after proper treatment and ascertaining its bacteriological quality for potability by retesting.

Note: Above sample/samples is/are not collected by this laboratory and result is/are as per submitted sample/samples.

Fee Rs. 340/-

Receipt No. : 7760768

Date : 18/07/2025


 Chief Bacteriologist
 State Public Health Laboratory, Pune